



अखिल भारतीय आयुर्वेद संस्थान

ALL INDIA INSTITUTE OF AYURVEDA (AIIA)

(आयुष मंत्रालय, भारत सरकार के अंतर्गत स्वायत्त संस्थान)

(An Autonomous Organization under the Ministry of AYUSH, Govt. of India)

A-G.19004/2/1/2011/AIIA

24 July, 2019

TENDER NOTICE

Sub: - Open Tender enquiry for the work of Annual Maintenance Contract of the – fire detection alarm system and firefighting system installed at AIIA Gautampuri sarita vihar New Delhi 110076 without spares.

The All India Institute of Ayurveda, Sarita Vihar, Gautampuri, New Delhi is inviting tender enquires for awarding the Annual Maintenance Contract for Fire Detection Alarm System and Firefighting System installed in the institute premises as mentioned in schedule of items, quantities, Technical Bid & price (Annexure I, II, III, IV- “A”, “B” & “C” and Annexure V “A” & “B”). The terms and conditions are mentioned below.

The Bids are to be submitted in 2 bid system in separate sealed envelope kept in big sealed envelope with requisite documents, EMD & Tender Fees etc. strictly in prescribed format and non-compliance of the same may lead to disqualification of the bidders.

The completed Quotations should be submitted in sealed covers, super scribed as “Open Tender enquiry for Annual maintenance contract of the – Fire Detection Alarm System and Firefighting System” addressed to Director, AIIA should reach this office on and before 26/08/2019 up to 5:30 PM and shall be opened tentatively on 27/08/2019. Submission of bids after due date will not be considered.

Director,
All India Institute of Ayurveda,
Gautampuri, Sarita Vihar, Delhi

गौतमपुरी, सरिता विहार, मथुरा रोड, नई दिल्ली -110076

Gautampuri, Sarita Vihar, Mathura road, NEW DELHI-110076

Website: aiiia.gov.in

Phone: 011-29948658

Fax: 011-29948888

GENERAL TERMS AND CONDITIONS

1. The complete tender document may be obtained from Admin office of AIIA, on payment of **Rs.500/-** in form of **demand draft (DD)/ Bankers cheque (Non-refundable)** in favour of the “**Director, AIIA**”. Details terms and conditions of said tender may also be downloaded from the website www.aiia.co.in and tender cost may be paid in form DD/ Banker cheque (Non-refundable) while submitting the tender. Bid will not be accepted without the cost of Tender document. The period of contract is for one year from the date of receipt of order.
2. The period of contract is for one year from the date of receipt of order. The same may be enhanced for further 1 more year; subject to satisfactory performances etc.
3. The firm shall engage all the men tools and plants required for the work. The AIIA will not supply any of the same except the materials for replacement during major repairs. The tenderer shall engage their own conveyance for transporting the men and materials, tools and plants required for the work to the AIIA site.
4. The quotation should be accompanied with an **EMD of Rs-75,000/ (Rupees Seventy-Five Thousand Only)** Payee Demand Draft in favour of “**The Director AIIA**” payable at **New Delhi only**. No other mode will be accepted.
5. The firm shall engage all the men tools and plants required for the work. The AIIA will not supply any of the same except the materials for the replacement. The tenderer shall engage their own conveyance for transporting the men and materials, tools and plants required for the work to the AIIA, S site.
6. The Tenderer shall take into account basic price, cost of labour, T&P, CGST/SGST as applicable, conveyance/ cartage etc. before quoting the rates. No extra claim what so ever in this regard shall be entertained. Parties are required to quote their Pan No. CGST no, SGST no., and PF Code.
7. The successful tenderer shall have to give performance security deposit amount of 5% of the total amount of the after adjusting the amount of Rs- 75000/, if already deposited along with the tender within one week from placing the order which will be refunded only after successfully and satisfactorily doing the said job of re-filling etc. Or after completion of satisfactory guarantee period of performance, whichever is later.
8. As per the AMC you are responsible for the maintenance of the fire detection alarm system and Firefighting systems installed at AIIA premises. The fire detection alarm system & Firefighting system are installed at Hospital Block & Administrative Block while the sprinkler System is installed in AIIA premises. The descriptions of the items covered in the AMC are given in Annexure- III.
9. The contract is for preventive as well as breakdown maintenances.
10. ELIGIBILITY CRITERIA
 - a.) Experience of having successfully completed similar works as servicing and maintenance of Firefighting Equipment's / Fire detection alarm system during last 6 years. The experience will be counted form 1st April 2013 and onwards. The company's turnover 40% of 3years, 60% of 2years and 80% in last year, total amount of 50 Lakh. Documentary proof for the above shall be produced along with the offer,

failure of which the offer may be disqualified. In case of Experience in Public / Private Ltd. The tenderer shall furnish completion certificate along with the copy of TDS certificate.

- b.) The comparative prices are to be quoted in the prescribed format as per Annexure V "A" and "B" in a separate envelope duly signed by the authorised bidder with company seal.
 - c.) Non submission of documentary evidence or quoted price in prescribed form may lead to rejection of the bidders bid and will not be considered.
11. The tenderer may inspect the premises during office hours on any working day for getting acquainted before submitting the quotations. Non- familiarity with the site condition will not be considered a reason either for extra claims or for not carrying out the work.
 12. AIIA reserves the right to reject all or any quotation wholly or partly without assigning any reason whatsoever.
 13. In case of unsatisfactory service, AIIA reserves the right to terminate the contract by giving 15 days, notice and forfeit the security deposit.
 14. The AMC shall be for one year and the AIIA reserves the right to enter into EMD for another year on the same terms and conditions depending on the service rendered by the contractor.
 15. Part quotations will be disqualified, the tenderer should quote for the complete scope of work, the validity of quotation should be 90 days from the date of opening of quotations.
 16. The contractor has to carry out the preventive maintenance on fortnightly basis or as directed by authorized officer on behalf of Director AIIA, shall deduct an amount of Rs.500/- (Rupees five hundred only) per day, if the preventive maintenance is not carried out on that particular day. The complaints/breakdown calls have to be attended within 2.00 hours positively. The contractor has to maintain a register for the periodical inspections, which have to be produced before Director AIIA and carry out the checks as per the preventive maintenance schedules as per scope of work and Annexure I & II. The contractor should depute qualified/experienced technicians for carrying out the preventive maintenance work.
 17. If the tenderer after award of work fails to undertake the job satisfactorily at any period of time or withdraws his services permanently or for more than three consecutive weeks, the Director AIIA, shall have right to cancel the contract and forfeit the security deposit/ due amount without assigning any reason.
 18. In case any further details are required, the same can be collected from the office of Admin block ground floor, AIIA, Gautampuri, Sarita Vihar, New Delhi-76 from 27 July 2019 to 26 August 2019 (Except Saturday/ Sunday & holiday) between 10:30 AM to 3:00 PM.
 19. While applying for the tender document, the intending tenderers shall finish proof of, experience certificates, works completed/ awarded, valid work contract tax/ SGST/CGST as applicable.


30. PAYMENT TERMS AND CONDITIONS;

* The payment to the agency will be made on quarterly basis at the end of each quarter against invoice with CGST/SGST, raised by the agency and based on past performance. The statutory deduction as applicable as per prevailing rates will be deducted before making the payment. Quarter shall mean three months.

* The maintenance charges quoted by the agency per item is on yearly basis inclusive of all taxes and levies applicable. No escalation of prices shall be permitted on any ground.

* The preventive maintenance shall be done as per attached periodical testing maintenance chart. The copy of service reports of that preventive maintenance shall also need to be submitted by the contractor at the time of submission of bill failing of which will cause detection of AMC premium charges for that quarter. The fire detection alarm, Firefight and fire extinguisher inventories of the Institute is schedule ANNEXURE'' III''

* It will be obligatory on the tenderer to signature the tender documents/ quotation for all the components & parts. After the work is awarded he will have to enter into an agreement for work awarded on a non- judicial stamp paper of requisite value at his own cost within ten days from date of receipt of acceptance order of before the work is undertaken.


24/7/19
Director,

All India Institute of Ayurveda,
Gautampuri, Sarita Vihar, Delhi

20. The tenderer must confirm their acceptance of the terms and conditions mentioned herein and enclosed documents. Each page of the original quotation document should be signed and returned back and this will form a part of the contract.
21. Complete tender document available on our website www.aiaa.gov.in and <https://eprocure.gov.in/epublish/app> also in addition to the CPP Portal. Any further corrigendum/ addendum to this tender document shall be made available on aforesaid website. It is therefore, requested that the bidders may regularly visit the website for checking any corrigendum/ addendum to this document.
22. In the event of any dispute the legal matter shall be subjected to the Jurisdictions of Delhi Court only.
23. All the communication with respect to the tender shall be addressed to: Director All India Institute of Ayurveda (AIIA) Sarita Vihar New Delhi
24. The work will be carried out as per specifications and by the directions of the director AIIA.
25. After completion of the work, one year guarantee of proper performance of equipment shall have to be given in writing by the bidder to the institute.
26. Special provision for micro & small enterprises:
Micro and small enterprises (MSEs) participating in the tender will be given benefit as per public, 2012. Further, the MSEs owned by SC/ST entrepreneurs will also be given benefits as per public procurement policy,2012
The definition of MSFs owned by SC/ST is as given under:
 - a) In case of proprietary MSE, proprietor shall be SC/ST
 - b) In case of partnership MSE, the SC/ST partners shall be holding at least 51% shares in the unit.
 - c) In case of private limited companies, at least 51% share shall be held by SC/ST promoters.
Document to claim benefits shall be enclosed along with offer.
27. Any parts taken out for repairing of changing or for any other purpose must be authorized by Director AIIA by valid gate pass. A logbook is to be maintained for keeping record of parts taken out/ returned back for record purpose. Any part taken out for repairing or changing or for any other purpose must be authorized by Director AIIA by valid gate pass.
28. The contractor should intimate the essentials and necessary major spare parts during contract period in the offer so that it can be considered and procured by AIIA for ready requirement.
29. In case any material/ property of the AIIA is damaged due to misuse or mishandling or carelessness by the Contractor or his employees, the Contractor will immediately inform the Director/ So Office or authorized Departmental Heads of Works division. In such a case, the contractor will be liable to replace the items at his own cost or the AIIA shall have the right to recover the loss from the contractor's bill. The decision of the AIIA in this matter will be final.

ANNEXURE "I"

Annual Maintenance Contract of Fire detection and Fire Fighting Systems installed at AIIA Complex, New Delhi as per details given below: -

1. GENERAL

The intending tenderer shall be deemed to have visited the site and familiarized themselves thoroughly with the site conditions before submitting their bid. No-familiarity with the site conditions will not be considered a reason either for extra claims or for not carrying out in strict conformity with specifications, drawings and bill of quantities and requirement. In case of any doubt or dispute as to the interpretation of any clause contained in, the decision of Director, AIIA shall be final and binding on the CONTRACTOR.

2. SCOPE OF WORK

- 2.1 The Scope of work mainly consists of job of safety, fire prevention and protection, firefighting and schedule and general maintenance of safety equipment and firefighting facilities installed at AIIA Complex, New Delhi. The maintenance of the system is to be carried out throughout the entire contract period of one year however rate should be quoted for one year. The maintenance job should be carried out as per the detail of the scope of work given below. Maintenance jobs shall be carried out as per instruction of Director given to the contractor's supervisor/personnel.

THE DETAILS OF FIRE FIGHTING EQUIPMENT AT AIIA consist of the following: -

2.2.

- i. Fire water network including hydrants and water monitors.
- ii. Fixed water spray system: At AIIA STP extension basement on different equipment.
- iii. Fire Alarm System: Manual fire break glass type has been provided at strategic points inside the building.
- iv. Different type of branches, Hoses and hose fittings.
- v. Three nos of Fire Water Pumps

2.3 To ensure proper operation 24X7 maintenance of safety and firefighting equipment installed and to carry out the fire fighting/rescue operation in case of fire of accident inside the complex area.

2.4 Various log books shall be maintained by the contractor supervisor/personnel. The copies of relevant pages of log books duly signed by the concerned staff/officers as required shall be submitted along with the bills, if required. No extra payment for maintaining the logbook will be made.

2.5 Log book format shall be submitted by the contractor and duly approved by the Director AIIA.

2.6 The logbook will generally contain status of equipment and system and maintenance carried out duly signed by contractor's personnel/supervisor and certified by Director AIIA, officer as required.

2.7 The scope of work for each type of equipment/ system shall be carried out weekly / monthly /quarterly / annual and bi- annual maintenance or actuation tests as listed ANNEXURE-I, II. &III.

- a) Service report and register must be got signed after every service by the officer in charge designated by the Director AIIA, for such purpose.
- b) In case of actuation of an extinguisher or fire smoke detector either for testing or due to actual fire, the contractor must inform the officer-in-charge of the equipment to be recharged, and get it entered in the service report/register, countersigned by the Director AIIA, Therefore, it will be the contractor's responsibility to provide necessary replacement with the correct type and the cost of material shall be reimbursed by AIIA.

Monthly discharges test at least on external hydrant and one internal hydrant (Preferably from top floor or terrace) by attaching single length of sire hose, with nozzle to check automatic staging of pump with hydrant operation.

2.8 PUMPS AND CONTROL

- a) Starter contracts cleaning once in a month
- b) Insulation resistance test of Pump, motor circuit etc.
- c) Any other inspection as contained in manufactures literature for pump and controls.

2.9 FIRE DETECTOR AND ALARM

- a) Monthly visual check of each detector (external check only)
- b) Quarterly cleaning of smoke/heat detector (removal of dirt, if any)
- c) Quarterly actuation of smoke detector by turn-at least one detector on each floor to be subjected to test.
- d) Circuit test/panel test-for fault and fire condition every month, for fault test and every quarter for fire condition.

2.10 Fire Extinguishers (Scope of Work)

- a) Arrangement of cleaning material, tool etc. at site shall be done by contractor.
- b) Annual maintenance contract also covers refilling of the fire extinguishers as per norms and requirement basis. However, the payment will be made on actual basis as per quoted rate in bill of Quantities.
- c) The re-filling work shall be carried out within 10 days from the date of intimation to the party.

ANNEXURE "II"

TESTING AND PREVENTIVE MAINTENANCE SCHEDULE

1. Fire extinguishers (CO2 gas, ABC, Trolley mounted) Monthly checks: -
 - A) Pressure is at recommended level or not
 - B) Nozzle, pipe or other discharging paths are not hindered any way.
 - C) The pin & tamper seal are intact.
 - D) There are no sign of abuse/ wear (dents, leaks)
 - E) Check full weight (quarterly)
 - F) Shaking of dry powder type to prevent powder form setting / packing
2. HYDRANT WET RISER SYSTEM
 - A) Fortnightly visual test/ check of external or internal hydrant valves, other washers etc. by turn, 2 hydrants per week
 - B) Monthly test of hose reel, hydrant control valve, outlets, with actual discharge test with water.
 - C) Monthly visual check of fire hose, including coupling / washers etc. With at least on third of total no. of hoses visual each month

HYDRANT WET RISER SYSTEM

Visual / Physical Check : Weekly to check washers, couplings, valves logo wheel check nuts etc.

Monthly visual check of Hose/ Hose Box for any damage rot/ rust etc. Monthly hose reel by actual actuation.

Pump/ jockey Pump : fortnightly physical check / greasing of nipples etc.

Automatic Start : Monthly check to rest automatic start of Jockey pump at present pressure and auto stop of jockey pump at present pressure.

For all tests, maintenance and up keep of the entire firefighting system at least 2 persons from contractor's side, one skilled another helper should be present in the work site at least twice in a month. The above are general checklists and test requirements etc. the contractor shall be bound for undertaking any other check / test which is necessary for efficient functioning of equipment / system, whether included in the above schedule or not.

APPENDEX-III

FIRE FIGHTING SYSTEM

1. Fire Pumps Electric –	75HP-	--	02 Nos
2. Jockey Pumps –do –	25 HP	--	02 Nos
3. Fire Pump for water curtain			
Electric –	100HP	--	01 Nos
1. Diesel Engine -	76.5 HP	--	01 Nos
2. 5. Terrace Pump _	12.5 HP	--	04 Nos
3. <u>Butter fly valve-</u>			
a. 200 dia (MM)-			04 Nos
b. 150 dia (mm) -			69 Nos.
c. 100 dia (mm) –			09 Nos.
d. 80 dia (mm) –			36 Nos
e. 50dia (mm) –			03 Nos
4. <u>Non Return Valve (N.R.V)</u>			
(a) 200 dia (mm)		–	01 nos
(b) 150 dia (mm)		–	54 nos
(c) 80 dia (mm)		–	06 nos
5. <u>Y- Stainer</u>			
(a).200 dia (mm)		–	02 Nos.
(b)100 dia (mm)		–	01 Nos.
(c)80 dia (mm)		–	05 Nos
(d)50 dia (mm)		–	02 Nos
6. Ball valve			
(a). 25 MM	–		114 Nos (114 Nos)
10. Alarm valve set (150 dia)	–		06 Nos
11. Flow switch (150 dia)	–		42 Nos
12. Deluse Valve set with Electric Solinoid Switch _			08 Nos
13. Hydrent Valve (landing valve) -			87 Nos.
14. Branch Pipe –			01 Nos.
15. Hose Pipe (15 mtr) –			97 Nos.
16. Fire shaft doors –			58 Nos.
17. Air Vessels with Air release valve –			16 Nos.
18. Four way (fire bridge) –			02 Nos.

19. Fire Bridge (FB) Suction – 01 Nos.
20. Cabinet Double Door – 21 Nos.
21. Diesel Tank 200 Litre – 01 Nos
22. Pressure Gauge – 70 Nos
- 23 Hose Reel Drum Set – 70 Nos
24. Fire Pump Panel (Electrical) – 03 Nos.

DETAILS OF FIRE EXTINGUISHER

(A) CO2 (BC) 4.5 kg	45 Nos.
(B) CO2 (BC) 22.5 kg	02 Nos
(C) Foam Type (AB) 09 Ltr	45 Nos
(D) Powder Type (ABC) 06 kg	10Nos
(E) Clean Agent – 04 kg	04 Nos.
(F) Clean Agent – 02 kg	05 Nos.
(G) Clean Agent – 06 kg	02 Nos.

FIRE DETECTION ALARM SYSTEM

Name of Items	Quantity	Make
1 Smoke detector	1816	Copper
2 Heat Detector	196	Copper
3 Response Indicator (RI)	433	Copper
4 Manual call point (MCP)	69	Copper
5 Hotter	69	Copper
6 Repeater Panel	02	Copper
7 Fire alarm detection panel	06	Copper

[On the letter head of firm]

Annexure – “IV A” (Technical Bid Form)

To,

Director,
All India Institute of Ayurveda,
New Delhi.

Dear Sir,

1. I/We..... Submitted the tender for Enquiry No. “TENDER FOR SUPPLY OF SECURITY TOOLS IN ALL INDIA INSTITUTE OF AYURVEDA, NEW DELHI AGAINST THE INQUIRY NO.” DUE ON.....,03:00 PM for Supply ofat AIIA, New Delhi”.
2. I/We thoroughly examines, understood and accepted terms & conditions given in the enquiry document, failing which my tender will be rejected out rightly.
3. I hereby furnish following details of my firm

GENERAL INFORMATION

- a) Name of the firm.....
- b) Address.....
- c) Telephone No., Working Fax & E-mail.....
- d) Person responsible for conduct of business/ head of the organization.....
- e) Valid VAT/ Sales Tax No.....
- f) IT PAN No.....
- g) Bank account Number / RTGS/NEFT.....
- h) Declaration that the firm has never been black listed/ debarred by any procurement agency / Govt. Organization in the required format (Annexure – IV A)
- i) I am submitting the checklist as per your Annexure. IV A (ii)

Date _____

(Signature of Authority Person with seal)

Place _____

Name

Phone No. E-mail ID.....

ANNEXURE – “IV B”

DECLARATION

Date.....

To,
The Director, AIIA,
New Delhi.

Dear Sir,

Ref.: Inquiry No.....dated.....

I/We.....hereby confirm that our firm has not been banned or blacklisted by any government organization / Financial institution /Court/ Public sector Unit/ Central Government and no police/ Vigilance enquiry/ criminal case is pending against us.

Signature of Authority Person.....

Place:

Name

Date:

Designation

Seal..

ANNEXURE "IV-C"

Check list of the Documents to be attached

Envelope "A" Technical Bid

The tenderer should submit the following certificates / documents for the items tendered in a separate envelope herein called envelope "A" (Technical Bid). All the documents should be attested by the authorized signatory of the firm with their official seal. The tender shall be liable to be rejected if following documents are not submitted with the envelope "A" (Technical Bid).

S. No.	Name of the Documents	Yes/ No.
1.	Forwarding letter of the firm.	
2.	Earnest Money Deposit Draft of Rs. 75,000/ (Rupees seventy-five thousand) payable to The Director, AIIA, New Delhi. Or Certificate of Exemption form EMD, if applicable	
3.	Cost of Tender (Demand Draft) in case downloaded from Internet.	
4.	Annexure IV (Technical Bid Format) duly filled and signed by authorized signatory with their official seal	
5.	Self-attested copy of valid VAT/Sales Tax No./GSTIN) etc.	
6.	Self-attested Copy of IT PAN No.	
7.	Self-attested copy of IT Return of last 5 years	
8.	Self-attested copies of award of work and their completion of more than 25 Lakh of last 5 years.	

Envelops "B" Financial Bid

1.	Annexure II (Price Bid Format) with all the papers duly filled and signed by authorized signatory with their official seal.	
----	--	--

Note:

All the papers in the document should be attested by the authorized signatory of the firm with their official seal.

Financial Bid will be opened for scrutiny, only when technical bid is found in order.

All prices should be quoted in Indian Rupees (INR) only. Price can be mentioned only up to two digits after decimal.

All prices are inclusive of all taxes, packing, freight charges and duties payable during the contract period. All prices will be including delivery services (unloading and uploading) at stores/ Hospital Premise AIIA.

Both the sealed envelopes (A & B) are to be put in bigger envelope which should also be sealed and duly super scribed "**TENDER FOR AMC FIRE FIGHTING AND FIRE DETECTION ALARM SYSTEM TO AIIA**"

Annexure "V-A"

Financial Prices of Fire Fighting system and Fire Alarm System in All India Institute of Ayurveda, Delhi - Comprehensive

1.	Annual Maintenance Contract of the "Fire Detection Alarm and Fire Fighting System including smoke detectors and sprinkler system installed at different location at AIIA Delhi mentioned in Annex. I, II & III. The spares required for maintenance of the systems (including replacement for the defective parts shall be provided by the AIIA. However, no labour charges for replacement/rectification are payable and are deemed to be included in the scope of work of AMC.			
2.	Refilling of foam type (AB) fire extinguisher of 09 litres Capacity and sticking of instructions label etc.	45		
3	Refilling of dry chemical powder type (ABC) Fire extinguisher of 06 kg capacity and sticking of instruction label etc.	12		
4	Refilling of carbon dioxide co2 (BC) type fire extinguisher 4.5 kg capacity and sticking of instructions label etc.	45+5 pota cabin		
5	Refilling of carbon dioxide co2 (bc) type fire extinguisher 22.5 kg capacity and sticking of instructions label etc.	02		
6	Refilling of fire finder suppression system and clean agent of 02 kg capacity Fire cylinder and sticking of instruction label etc.	05		
7	Refilling of fire finder suppression system and clean agent of 04 kg capacity Fire cylinder and sticking of instructions label etc.	04		
8	Refilling of fire finder suppression system and clean agent of 06 kg capacity Fire cylinder and sticking of instruction label etc.	02		

Note: The above prices quoted should be inclusive of GST / other taxes as applicable. No escalation in prices is acceptable once quoted.

(Signature of the Bidder with company seal and date)

Annexure "V-B"

Financial Prices of Fire Fighting system and Fire Alarm System in All India Institute of Ayurveda, Delhi – Non- Comprehensive

S. No.	Description of work	Qty.	Rate per unit	Amount (Rs.)
1.	Annual Maintenance Contract of the "Fire Detection Alarm and Fire Fighting System including smoke detectors and sprinkler system installed at different location at AIIA Delhi mentioned in Annex. I, II & III. The spares required for maintenance of the systems (including replacement for the defective parts shall be provided by the AIIA. However, no labour charges for replacement/rectification are payable and are deemed to be included in the scope of work of AMC.			
2.	Refilling of foam type (AB) fire extinguisher of 09 litres Capacity and sticking of instructions label etc.	45		
3	Refilling of dry chemical powder type (ABC) Fire extinguisher of 06 kg capacity and sticking of instruction label etc.	12		
4	Refilling of carbon dioxide co2 (BC) type fire extinguisher 4.5 kg capacity and sticking of instructions label etc.	45+5 pota cabin		
5	Refilling of carbon dioxide co2 (bc) type fire extinguisher 22.5 kg capacity and sticking of instructions label etc.	02		
6	Refilling of fire finder suppression system and clean agent of 02 kg capacity Fire cylinder and sticking of instruction label etc.	05		
7	Refilling of fire finder suppression system and clean agent of 04 kg capacity Fire cylinder and sticking of instructions label etc.	04		
8	Refilling of fire finder suppression system and clean agent of 06 kg capacity Fire cylinder and sticking of instruction label etc.	02		

Note: The above prices quoted should be inclusive of GST / other taxes as applicable. No escalation in prices is acceptable once quoted.

(Signature of the Bidder with company seal and date)

